

Green Switch

HD/HC/HS4658 - L/N/NT4658N - AM5658

Description


This device features a PIR and US (ultrasound) movement detector, and a brightness sensor for automatic activation of various types of loads following the detection of a movement, and a brightness level lower than the set level. The enabling/disabling of the load can also be performed manually using the appropriate front pushbutton and/or using an external BUS control device. It is possible to configure several operating modes; for the detailed descriptions see page 4.

Technical data

Voltage:	27 V=
Absorption:	17 mA
Collegamento tra rilevatore e attuatore:	BUS SCS connector
Sensor type:	movement detector (PIR+US) with 180° detection angle and brightness sensor.
Flush mounted box depth:	40 mm
Weight:	60 g
Shock resistance:	IK04
Penetration of solids and liquids:	IP20
Time delay:	5 sec. - 59 min. 59 sec
Brightness:	5 lux - 1275 lux
Operating temperature:	(- 5) - (+ 45)°C
Storage temperature:	(- 20) - (+ 70)°C


Dimensional data

Size: 2 flush mounted modules




A	B	C
45	45	51

Wiring diagram



Front view







Legend

1. PIR sensor
2. LEARN LED
3. US sensor
4. ON-OFF key
5. LEARN key
6. Movement detector sensor (under the lens)
7. Infrared transmitter (under the lens)
8. Light sensor

Installation

Detector position



Position the detector so that it is not affected by the artificial light already present in the room.

Configuration

Detection parameters:

Sensor parameters		Preset value	Adjustable parameters	Configuration tools		Available in	
				BMS04001	BMS04003	Distributed mode	Central mode
Time delay		15 mn	3,5,10,15,20 min 30s - 255 h 59 min 59s	–	✓	✓	✓
Sensitivity		PIR (molto alta) / US (alta)	Low, medium, high, very high	✓	✓	✓	✓
Mode	Auto	Not active	Activate/Deactivate	✓	✓	✓	–
	Walkthrough	Active	Activate/Deactivate	✓	✓	✓	–
	Eco	Not active	Activate/Deactivate	✓	✓	✓	–
Detection mode	Iniziale	PIR and US	PIR and/or US, PIR, US	✓	–	✓	Available but not separate
	Maintenance	PIR or US	PIR and/or US, PIR, US	✓	–	✓	
	Retrigger	PIR or US	PIR and/or US, PIR, US, Deactivate	✓	–	✓	
Alarm		Not active	Activate/Deactivate	✓	–	✓	–

Time delay: the time delay after which the load is switched off, if no movement is detected and the lighting level is sufficient

Sensitivity: detection interval setting.

Mode:

Auto:

- Automatic switch on:
- upon detection of a movement if the level of natural light is insufficient.
- Automatic switch off:
- if no movement is detected, at the expiry of the time delay set;
 - or if the level of natural light is sufficient (set brightness threshold).
- Another detection causes automatic switching on if the light is insufficient

Walkthrough:

- If a movement is detected for a period of time of less than 20", the sensor will switch the load off after 3 minutes;
- Otherwise the load will be switched off after the set time delay. .

Eco:

- Manual switching on/automatic switching off:
- if no movement is detected, at the expiry of the time delay set;
- After switching off, if the detector detects a movements within 30 seconds the lights automatically come on; after 30 seconds the lights must be switched on manually.

HD/HC/HS4658 - L/N/NT4658N - AM5658

Detection mode:

Initial detection: the lights are switched on upon detection, if the natural light is below the brightness threshold.


Maintenance: the lights stay on if another movement is detected.


Retrigger: If the sensor detects a movement during the 30 s immediately after switching off of the load, this is immediately switched on again. After the 30 s the sensors returns to normal operation. After 30 seconds the device must be switched on manually

Alarm: before the device is switched off a sound signal is emitted (1 minute, 30 seconds, and 10 seconds before switching off),


Brightness parameters:

Sensor parameters	Preset value	Adjustable parameters	Configuration tools		Available in	
			BMS04001	BMS04003	Distributed mode	Central mode
Brightness threshold	300 lux	20, 100, 300, 500, 1000 lux 0 - 1275 lux	– ✓	✓ –	✓	–
Advanced mode	Calibration	– 0 - 99995 lux	✓	–	✓	✓
	Brightness adjustment	Not active Activate/Deactivate	✓	–	✓	–
	Light contribution	Automatic Automatic - 1275 lux	✓	–	✓	–

 **Brightness threshold:** value at which the lights come on if the brightness level is below the set values, and switch off if above this threshold.


 **Brightness adjustment:** function for the switching off of the lights 10 minutes after the brightness threshold set is reached. In addition to this time there is a further time interval (safety threshold to avoid inappropriate switching off).

Advanced mode:

 **Calibration:** For calibration to be performed, it is necessary to measure the brightness level present using a lux metre, sending the value to the sensor using a configuration remote control (BMS04001).

Light contribution: amount of supplementary light supplied by the lighting device switched on.

Modification of the parameters using the configuration tools



• **BMS04001** : advanced configuration tool

• **BMS04003** : simplified configuration tool

When the detector receives an IR command from a configuration tool, it emits a sound that confirms that the modification has been acquired.



Return to the factory settings:

1st pressure: press and release LEARN, the LED flashes slowly.

2nd pressure: press and hold down LEARN for 10 seconds until the LED starts flashing quickly.

Performance

Height



My Home configuration

If the sensor is installed in a My Home system, it can be configured in two ways:

- PHYSICAL CONFIGURATION, connecting the configurators to the relevant sockets;
- VIRTUAL CONFIGURATION, connecting the system to the PC, using the kit Cat. no. 3503N, or the Web server. In this case the virtual configurator software must be installed on the PC.

Note: when configuring the product using the PHYSICAL CONFIGURATION or the VIRTUAL CONFIGURATION, it will not be possible to use the configuration remote controls. Therefore, the advanced functions (not settable using configurators) will not be accessible.

Physical configuration

The sensor parameters are defined by 6 configurator sockets and the functions depend on the operating mode:

Light point: PL = 1 – 9

Mode: M = 0 – 4

Sensitivity of the movement sensor: S = 0 – 3

Control timer: T = 0 – 9

Sensitivity of the light sensor: D = 0 – 5

Warning: the addresses A = 0 and PL = 0 do not exist

Possible function	Configurator mode
The sensor controls the light unit, the address of which defined in A and PL. When a movement is detected, and if the brightness level is below the configured value, the system switches the specified light unit and keeps it on until the expiry of the period configured using the configurator in T (automatic mode). The Sensitivity of the PIR movement detector is configured using the configurator in S. For appropriate operation, the Sensitivity of the light sensor must be configured using the configurator in D. If a user manually switches off the lights, a control action can be used to disabled the movement detector until a movement is detected, for a period set by T.	0
In this mode, the sensor only works based on the light conditions, and the movement sensor is disabled. When the brightness falls below the threshold configured, the system switches on the light unit, switching it off again when the brightness exceeds the set threshold (automatic mode). Configurator A = 1 and PL = 1-9, configurators GEN, AMB (room), and GR cannot be connected. In this mode, configurators S and T are not connected.	1
In this mode the sensor does not manage the lights directly, but sends movement and brightness signals to the scenario programmer MH200N. In this case, the sensor address is entered in A and PL and must be unique inside the system. Therefore it is not possible to connect configurators GEN, AMB, and GR. In this mode the S and T configurators are not connected because these parameters are directly managed by the scenario programmer.	2
In this mode the system directly manages a light unit, ensuring a consistent brightness level inside the room (this mode is only effective if the sensor manages the dimmer). The system switches the lights on when a movement is detected and keeps them on based on the presence of people and the lighting threshold configured (automatic mode). When a movement is detected, and if the brightness level is below the configured value, the system switches the specified light unit on and keeps it on until the expiry of the period configured using the configurator in T. During operation the sensor keeps a consistent brightness level, depending on the configurator in D. For example, when the brightness of the natural light increases, the sensor reduces the brightness of the light unit controlled. For appropriate operation, the brightness Sensitivity threshold of the sensor must be configured using the D configurator. The threshold value can be modified using a brightness control. The new value is then configured as the new sensor threshold, until the next activation.	3
In this mode, the sensor only operates on the basis of the brightness conditions, and directly manages a light unit to ensure a consistent brightness level inside the room (this mode is only effective if the sensor manages the dimmer). The movement sensor is disabled. The lights are manually switched on, and automatically switched off by the sensor, based on the brightness threshold configured (eco mode). Therefore, when the lights are off, the sensor does not switch them on; but it waits for the user to switch them on manually. During operation, the sensor keeps a consistent brightness level, depending on the configurator in D. For example, when the brightness of the natural light increases, the sensor reduces the brightness of the light unit controlled. When the lights are off, if the level of natural light decreases, the sensor does not switch them on. but it waits for the user to switch them on manually. For appropriate operation, the brightness Sensitivity threshold of the sensor must be configured using the D configurator. The threshold value can be modified using a brightness control. The new value is then configured as the new sensor threshold, until the next activation.	4

Warning: to manage scenarios using the sensor signals, through the MH200N scenario programmer, the sensor must be configured in Mode 2.

HD/HC/HS4658 - L/N/NT4658N - AM5658

1) Duration of the light timer based on the configurator connected to T:

Configurator in T	Light timer in minutes
No configurator	15
1	0.5
2	1
3	2
4	5
5	10
6	15
7	20
8	30
9	40

2) Sensitivity PIR movement detector based on the configurator connected to S:

Configurator in S	Sensitivity
No configurator	Low
1	Medium
2	High
3	Very high

3) Sensitivity of the light sensor based on the configurator connected to D:

Configurator in D	Sensitivity in lux
No configurator	300
1	20
2	100
3	300
4	500
5	1000

Virtual configuration

The virtual configurator software can offer all the functions listed below:

- brightness/movement detector, local
- brightness sensor, local
- movement detector, local
- brightness/movement detector, central
- brightness sensor, central
- movement detector, central
- IR PLUS scenario control

Configuration of the light management function

If the sensor is used in the Lighting Management system, it can be configured with the following modes:

- **Plug&Go, Push&Learn** (see the specific technical manual)

- **Project&Download.**

The virtual configurator software can offer all the functions listed below:

- brightness/movement detector, local
- brightness sensor, local
- movement detector, local
- brightness/movement detector, central
- brightness sensor, central
- movement detector, central
- IR PLUS scenario control

For more detailed information on the functions, see the glossary at the beginning of the Technical Sheets section.

Maintenance

Keep the lenses clean.

Clean the surface using a cloth.

Do not use: acetone, detergents for removing tar, or trichloroethylene.

Maintenance using the following products:

- hexane (En 60669-1)
- methylated spirit
- soapy water
- diluted ammonia
- bleach, diluted 10%
- glass detergents

Warning : an initial test is required in order to use other special maintenance products.

Standards

Directive: EC
 installation norms: NFC 15-100
 Product norms: IEC 60669-2-1

Environmental standards:

- UE 2002/96/EC directive:
- UE 2002/95/EC directive:

- Standard:

RAEE (electric and electronic device waste).
 RoHS (restriction on the use of dangerous substances)
 ERP (public buildings)
 ERT (buildings used as workplaces)
 IGH (very high buildings)