



DECLARATION DE CONFORMITE DECLARATION OF CONFORMITY

N° A 96 / 2009

APPAREIL(S) : Mécanismes de commande, prises de courant, plaques et cadre
SAMPLE DESCRIPTION : saillie SOLIROC

REFERENCE(S) : 77811-77821-77812-77814-77813-77822-77825-77827-77841-77842-
77844-77843-77823-77831-77833-77832-77851-77852-77853-77890-
REFERENCE(S) : 77892

CARACTERISTIQUES : IP55/IP20 IK10
RATED CHARACTERISTICS :

CET (CES) APPAREIL(S) EST (SONT) CONFORME(S) :
THIS (THESE) DEVICE(S) IS (ARE) IN ACCORDANCE WITH :

A la norme NF EN 60695.2.11 (2001).


Sévérité 850°C/30s pour les pièces en matériaux isolants maintenant en place les parties actives

Sévérité 650°C/30s pour les autres pièces en matériaux isolants

Cette déclaration comprend : 1 page

This declaration contains : 1 page

Date de délivrance : 03/09/2009
Issue date :



Responsable du Laboratoire Produits Central
Head of test Laboratory
Jacques BARBANCEYS

La reproduction de ce document n'est autorisée que sous la forme de fac-similé photographique intégral. Toute reproduction partielle ou toutes insertions de résultats dans un texte d'accompagnement en vue de leur diffusion doit recevoir un accord préalable et formel de LEGRAND.
Ce document résulte d'essais effectués sur un échantillon. Il ne préjuge pas de la conformité des produits fabriqués à l'objet essayé.
This document shall not be reproduced, except as a complete photographic facsimile. Any partial reproduction, as well as the insertion of any results into an accompanying text for distribution, requires the prior written approval of LEGRAND.

This document contains results related only to the items tested. It does not imply the conformity of the whole production to the items tested.

LEGRAND - 128, Avenue du Mal-de-Lattre-de-Tassigny - F 87045 LIMOGES Cedex - Tél. : (33) 05.55.06.85.92