

Rigid walls and flexible walls

Minimum wall thickness	≥ 100 mm
Ø cable	OD ≤ Ø 21 mm
Cable loading	0% to 100%
Opening size	Ø152 mm - Ø155 mm
Performance	EI 90 / E 120
Fire resistance	EN 1366-3
Classification	EN 13501-2

Not at scale. Units in millimeters

Please refer to the CM350701 Installation Sheet

