

Certifications

Fire Resistance : EN 1366-3






Classification : EN 13501-2

EZ-PATH Systems	Ø Cables (mm)	Flexible wall		Rigid wall			Rigid Floor
		≥100mm	≥122mm	≥100mm	≥122mm	≥150mm	≥150mm
1 or 2 x CM250018 (grouted) * <i>1 or 2 x EZD33T (grouted) *</i>	OD ≤ Ø 21	-	-	-	-	EI90 / EI120	-
1 x CM250018 + CM250240 <i>1 x EZD33T + EZP133CWT</i>	OD ≤ Ø 21	EI60 / EI120 *	EI120	EI60 / EI120 *	EI120	EI120	-
	OD ≤ Ø 50	-	-	-	-	EI60 / EI120	-
2 x CM250018 + CM250120 <i>2 x EZD33T + EZP233WT</i>	OD ≤ Ø 21	-	EI120	-	EI120	EI120	-
	OD ≤ Ø 50	-	-	-	-	EI60 / EI120	-
3 x CM250018 + CM250130 <i>3 x EZD33T + EZP333WT</i>	OD ≤ Ø 21	-	EI120	-	EI120	EI120	-
	OD ≤ Ø 50	-	-	-	-	EI60 / EI120	-
4 x CM250018 + CM250140 <i>4 x EZD33T + EZP433WT</i>	OD ≤ Ø 21	-	EI120	-	EI120	EI120	-
	OD ≤ Ø 50	-	-	-	-	EI60 / EI120	-
7 x CM250018 + CM250170 <i>7 x EZD33T + EZP733WT</i>	OD ≤ Ø 21	-	EI120	-	EI120	EI120	-
	OD ≤ Ø 50	-	-	-	-	EI60 / EI120	-
1 x CM250018 + CM250220 <i>1 x EZD33T + EZP133KT</i>	OD ≤ Ø 21	-	-	-	-	-	EI120

All EZ-Path systems are approved empty up to 100% fill of cables

Please refer to the corresponding Application Data Sheet and Installation Sheet for more additional information about the installation method

* Pending CE-Marking certification. These systems are classified per the EN13501-2

CM250018 + CM250240 EZD33T + EZP133CWT 	CM250018 + CM250130 EZD33T + EZP333WT 	CM250018 + CM250140 EZD33T + EZP433WT 	CM250018 + CM250170 EZD33T + EZP733WT 	CM250018 + CM250220 EZD33T + EZP133KT 
CM250018 + CM250120 EZD33T + EZP233WT 