

128, Avenue du Maréchal de Lattre-de-Tassigny - 87045 Limoge Cedex - FRANCE
france@legrandcablemanagement.fr www.legrandcablemanagement.fr

DECLARATION OF PERFORMANCE

according to Annex III of the Regulation (EU) Nr. 305/2011 (Construction Products Regulation) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

EZ-Path® Fire-Rated Pathway (Series 33 and Series 44+)

Certificate of constancy of performance UKCA 0843-CPR-1140

1. **Unique identification code of the product-type** : EZ-Path® Fire-Rated Pathway (Series 33 and Series 44+).
2. **Type, batch or serial number allowing identification of the construction product as required pursuant to Article 11(4):**
See batch number displayed on the product.
3. **Intended use or uses of the construction product** : Cable management firestop device (cable box).
Field of application has to comply with the content of the 0843-UKTA-22/0019
4. **Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):** LEGRAND SNC, 128, Avenue de Lattre-de-Tassigny - 87045 LIMOGES Cedex – France
5. **Name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):** N.A.
6. **System of Assessment and Verification of Constancy of Performance of the construction product** : System 1
7. **Designated standard:** N.A.
8. **UK Assessment Document** : EAD 350454-00-1104, Fire stopping and fire sealing products – Penetration seals
United Kingdom Technical Assessment (UKTA) : 0843-UKTA-22/0019
Technical Assessment Body : UL International (UK) Ltd
Approved body : UL International (UK) Ltd

9. **Declared performance:**

Characteristics	Declared performance / Harmonised technical specification
Reaction to fire	Class E according to EN 13501-1
Resistance to fire	Performance and field of application in accordance with EN 13501-2. See 0843-UKTA-22/0019
Dangerous substances	See 0843-UKTA-22/0019
Durability and serviceability	Y ₂ in accordance with EAD 350454-00-1104
Other	Not applicable / No performance determined

The performance of the product identified above is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

Varese, 21/11/2022

Page 1/1

Enrico Bussolini

R&D Director

